



Linda S. Adams
Agency Secretary

California Regional Water Quality Control Board North Coast Region William R. Massey, Chairman

www.waterboards.ca.gov/northcoast
5550 Skylane Boulevard, Suite A, Santa Rosa, California 95403
Phone: (877) 721-9203 (toll free) • Office: (707) 576-2220 • FAX: (707) 523-0135



Arnold
Schwarzenegger
Governor

August 28, 2006

Santa Rosa Department of Public Works
Pump Station No. 6
5200 Montgomery Drive, Santa Rosa
Case No. 1TSR358

Notice of Consideration of No Further Action

Internet Posting Date August 28, 2006
End of Comment Period September 27, 2006

Problem Description

The City of Santa Rosa removed and replaced an underground diesel storage tank system in February 1999. The tank system provides emergency backup to electric pumps during power outages. A minor release of diesel fuel was discovered at a pipe fitting adjacent to the pump building.

Remedial Actions Completed

Soil samples were collected as required by the Santa Rosa Fire Department. Stained soil beneath the pipe fitting was limited and removed by hand using a shovel. On March 2, 1999, the excavated area was dewatered of approximately 29,000 gallons and groundwater was allowed to recover. A post cleanup water sample was collected, which contained no detectable levels of contamination. Approximately 40 cubic yards of soil was removed including the soil removed for the entire tank system upgrade work and the impacted soil at the pipe leak location.

Water Quality Objectives

The post cleanup groundwater sample contained no detectable levels of contamination. Therefore, water quality objectives were met.

Period for Public Review and Comment

The Regional Water Board records for 5200 Montgomery Drive, Santa Rosa are contained in the file known as the SRDPW Pump Station No 6 and case No. 1TSR358, which may be reviewed at the North Coast Regional Water Quality Control Board, 5550 Skylane Boulevard, Suite A, Santa Rosa. Appointments are recommended and can be arranged by calling (707) 576-2220. Unless comments are received with new significant information within 30-days of the date of posting, this case will be closed with no further action required. Written comments may be sent to:

North Coast Regional Water Quality Control Board
Attention: Joan Fleck
5550 Skylane Boulevard, Suite A
Santa Rosa, CA 95403

Joan Fleck can also be reached at (707) 576-2675, or by e-mail at JFleck@waterboards.ca.gov.

082806_LAG_SRDPW#6_PN

California Environmental Protection Agency

Recycled Paper